

# CERTIFICATE

**TÜV NORD CERT GmbH**  
herewith declares that

**Slenergy Technology (A.H.) Co., Ltd.**  
NO. 120 Yongyang Road, Chuzhou City,  
Anhui Province, China

is authorized to provide the product mentioned below with the mark as illustrated:

**Description of product (details see Annex 2):**

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**



Valid from: 2023-08-07  
Valid until: 2026-11-07

Certification program:	P12-VA-01 Rev. 17 09.20
Certification fundamental(s):	IEC / EN 61215-1:2016; IEC / EN 61215-1-1:2016; IEC 61215-2:2016 / EN 61215-2:2017 + AC:2017 + AC:2018; IEC 61730-1:2016 / EN IEC 61730-1:2018 + AC:2018; IEC 61730-2:2016 / EN IEC 61730-2:2018 + AC:2018.
Registered No.:	44 780 23 406749 - 251
Manufacturer:	see Annex 1
Test Report No.:	492012614.001
File No.:	PVP07135/23P



**TÜV NORD CERT GmbH**  
**Certification Body**  
**Consumer Products**

Essen, 2023-08-07



Please also pay attention to the information stated overleaf.

**Manufacturer:**

Manufacturer: **Jiangsu Reesun Solar Technology Co., Ltd.**  
No.1 Nanjing Road, Jianhu Economic Development Zone  
Yancheng City, Jiangsu Province, P.R. China

Factory inspection report no.: 862010577.002

**Remark:**

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.

A handwritten signature in blue ink, appearing to read "Rolfen Miao".

**TÜV NORD CERT GmbH**  
**Certification Body**  
**Consumer Products**

**Description of product(s):**

Module types:	<b>PV Modules with Half-cut 182mm Mono-crystalline Silicon Solar Cells:</b> 144 cells: SL-144PA-xxxR (xxx=510-540, in steps of 5) 132 cells: SL-132PA-xxxR (xxx=470-495, in steps of 5) 120 cells: SL-120PA-xxxR (xxx=425-450, in steps of 5) 108 cells: SL-108PA-xxxR (xxx=385-405, in steps of 5)
Maximum system voltage:	1500V
Fuse rating:	25A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)
Module types:	<b>PV Modules with Half-cut 182mm TOPCon Mono-crystalline Silicon Solar Cells:</b> 144 cells: SL-144NA-xxxR (xxx=550-580, in steps of 5) 132 cells: SL-132NA-xxxR (xxx=510-530, in steps of 5) 120 cells: SL-120NA-xxxR (xxx=460-480, in steps of 5) 108 cells: SL-108NA-xxxR (xxx=410-430, in steps of 5)
Maximum system voltage:	1500V
Fuse rating:	25A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

## Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.



**TÜV NORD CERT GmbH**  
Certification Body  
Consumer Products