



**BUREAU
VERITAS**

Certificate of compliance

Applicant: TSUNESS Co., Ltd
2nd Floor, Building 2, No. 55 Aigehao Road, Weitang Town, Xiangcheng District
Suzhou City, Jiangsu Province
P.R. China

Product: Photovoltaic (PV) inverter

Model: TSOL-MS800 TSOL-MS800 Balcony
TSOL-MS700 TSOL-MS700 Balcony
TSOL-MS600 TSOL-MS600 Balcony

The device is designed to work as a generation unit of the type: A

Inverter for single-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point
- 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

DIN VDE V 0124-100:2020 (5.5.2.1 Functional safety of network and system protection)

Grid integration of generator plants - Low-voltage - Test requirements for generator units to be connected to and operated in parallel with low-voltage distribution networks

Commission Regulation (EU) 2016/631 of 14 April 2016

Establishing a network code on requirements for grid connection of generators (NC RFG).

Type approval for generation units to use in Type A. *

* cl. 4.5 only limited dynamic grid support was tested

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: CJAH-ESH-P23071884

Certification Program: NSOP-0032-DEU-ZE-V01

Certificate number: U24-0579

Date of issue: 2024-07-04

Certification body



Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065

Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH



**BUREAU
VERITAS**

Annex to the EN 50549-1 certificate of compliance No. U24-0579

Appendix

Extract from test report according to EN 50549-1

No. CJAH-ESH-P23071884

Type Approval and declaration of compliance with the requirements of EN 50549-1 and Commission Regulation (EU) 2016/631 of 14 April 2016

Manufacturer / applicant	TSUNESS Co., Ltd 2nd Floor, Building 2, No. 55 Aigehao Road, Weitang Town, Xiangcheng District Suzhou City, Jiangsu Province P.R. China			
Micro-generator Type	Photovoltaic inverter			
	TSOL-MS800	TSOL-MS700	TSOL-MS600	TSOL-MS800 Balcony
Photovoltaic (DC)				
MPP DC voltage range [V]	16-60	16-60	16-60	16-60
Max DC voltage [V]	60	60	60	60
Input DC current [A]	2*14	2*14.	2*14	2*14
Connection (AC)				
Output AC voltage [V]	L/N/PE, 230 Va.c., 50/60 Hz	L/N/PE, 230 Va.c., 50/60 Hz	L/N/PE, 230 Va.c., 50/60 Hz	L/N/PE, 230 Va.c., 50/60 Hz
Rated AC current [A]	3,48	3,04	2,61	3,48
Active Power [W]	800	700	600	800
	TSOL-MS700 Balcony	TSOL-MS600 Balcony	--	--
Photovoltaic (DC)				
MPP DC voltage range [V]	16-60	16-60	--	--
Max DC voltage [V]	60	60	--	--
Input DC current [A]	2*14	2*14	--	--
Connection (AC)				
Output AC voltage [V]	L/N/PE, 230 Va.c., 50/60 Hz	L/N/PE, 230 Va.c., 50/60 Hz	--	--
Rated AC current [A]	3,04	2,61	--	--
Active Power [W]	700	600	--	--
Firmware version	V1.0			

Description of the structure of the power generation unit:

The power generation unit is equipped with a DC and line-side EMC filter. The power generation unit has galvanic isolation between DC input and AC output (HF transformer). Output switch-off is performed with single-fault tolerance based on the inverter bridge and one series-connected relay in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.



BUREAU
VERITAS

Annex to the EN 50549-1 certificate of compliance No. U24-0579

Appendix

Extract from test report according to EN 50549-1

No. CJAH-ESH-P23071884

Note:

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019 Commission Regulation (EU) 2016/631 of 14 April 2016. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.